



Application of GREEN Ice Thermal Storage System for Peaking Gas Turbine Power Plants

Cooling Solutions



Stan Rott

MAY 10-12, 2011 * Rosemont, Illinois * Donald E. Stephens Convention Center



Outline

- Introduction to Turbine Inlet Cooling (TIC) – Technologies Overview
- Existing Plant Characteristics
- Thermal Energy Storage (TES) Selection Criteria
 - Chilled Water vs. Static Ice vs. Dynamic Ice
- Vacuum Ice Maker (VIM) Operation
- Results
 - Required modifications
- Conclusions
- Q&A




Terminology

- Ice Slurry
- Vacuum Ice Maker (VIM)
- Thermal Energy Storage (TES)
- “On-Demand” Chillers
- Static Ice
- Dynamic Ice
- Turbine Inlet Cooling (TIC)



Introduction

- Thermal Energy Storage (TES) for Turbine Inlet Cooling (TIC)
 - Combustion Turbine (CT) – ISO rated conditions: 59°F and 14.7psig
- Rate structure; TIC capital cost; Operation & Maintenance, Efficiency, Modularity & Expandability



Introduction

- TIC with Mechanical Chillers
 - “On-Demand” cooling – follows variable load
 - 45°F water supply temperature & de-rated conditions
 - Parasitic power consumption
- Ice Based TES Systems
 - Low temperature refrigerant & very de-rated conditions
 - Heat transfer surface area with high capital cost
 - Internal vs. External melt systems
- Ice Slurry Systems
 - Increased heat transfer without a HT surface area
 - No insulating effect from accumulating ice
 - Variable & Rapid discharge capabilities




Introduction

- TES (any type) Benefits for TIC:
 - Refrigeration equipment smaller capacity & footprint
 - Parasitic load shifted to off-peak hours
 - Revenue recovery maximized during on-peak hours
 - Low water and CT air supply temperatures
 - Increased level of redundancy
 - Variable & rapid discharge (dynamic ice TES systems)



Existing Plant - LM6000 SPRINT™



- LM6000 SPRINT™
 - GT Combustor temp.: 1,600°F
 - Heat Rate: 8,900 Btu/kWh
 - Plant efficiency: ~ 38%
 - SPRINT system: compressor High Pressure injection of demineralized water
- ASHRAE TIC Guidelines:
 - Ambient temp.: $T_{DB}=91^{\circ}\text{F}$, $T_{WB}=74^{\circ}\text{F}$,
 - Optimal inlet air temp.: $T_{WB}46^{\circ}\text{F}$




$$Q = \dot{m}(h_1 - h_2) = 291 \left[\frac{\text{lbs}}{\text{sec}} \right] * 3,600 \left[\frac{\text{sec}}{\text{hour}} \right] * (37.8 \left[\frac{\text{Btu}}{\text{lbs}} \right] - 18.2 \left[\frac{\text{Btu}}{\text{lbs}} \right]) * \frac{1}{12,000 \left[\frac{\text{Btu}}{\text{tonR}} \right]} = 1,711 \text{ tonR}$$

Existing Plant - LM6000 SPRINT™

- Annual hourly data
 - Turbine gross electric power output [MW]
 - Turbine net electric power output [MW]
 - Compressor inlet temperature [°F]
 - Compressor inlet pressure [psig]
 - Ambient T_{DB} [°F] & Relative Humidity [%]



Existing Plant - LM6000 SPRINT™



- Compressor Inlet Temp
 - T_{WB} : 46°F
 - Generator limitations
 - T_{WB} : 42°F
 - PF: above 0.85



TES Selection Criteria

Pros

- Chilled Water TES
 - Redundancy
 - Low first cost
 - Simple integration
- Static Ice TES
 - Redundancy
 - Relatively low first cost
 - Low supply temperatures
- Dynamic VIM Ice TES
 - Redundancy
 - No internal heat transfer surfaces
 - Simple & low cost TES tank
 - Water as only refrigerant


Cons

- Complex & expensive TES tank
- Large TES tank footprint
- Maximum water supply temp. of 39°F
- TES Tank with internals and moving parts
- Very low refrigerant temp.: 14°F - 22°F
- Specialized refrigerants, e.g. ammonia
- Limited heat transfer surface area
- Little known TIC experience
- Requires dedicated chillers
- Large equipment footprint



VIM TES Operation

- Process
 - Inside the VIM freezer, water is at "triple point" where all 3 phases exist in equilibrium, exposed to deep vacuum
 - The vacuum forces a small part of the water to evaporate while the remaining water freezes forming Ice Slurry, a water-ice mixture
 - The slurry is pumped from the freezer into the TES tank until ice concentration reaches 50%
- VIM employs water as the only refrigerant – Environmentally friendly – GREEN solution




- Power consumption 0.38kW/Ton (VIM only)
- Pumpable and non-coagulative Ice Slurry
- Small ice crystal size: 0.02– 0.04 inches
- Variable & rapid discharge capabilities



Proposed Configuration

- Existing equipment
 - 2,000 Ton electric-driven centrifugal chiller
- New equipment
 - VIM, TES Tank, HX's, pump, piping & controls



TES Operation Cycle

- Off peak tariff hours: 10:00pm – 8:00am
- Turbine operation duration: 8 hours
 - *Daily Cooling Demand = 8hours * 1,750Ton = 14,000Ton*
 - *Weekend Cooling demand = 5hours * 1,750Ton = 8,750Ton*

[TR-h]	Mon	Tue	Wed	Thu	Fri	Sat	Sun
TES Cap	30,000	26,000	22,000	18,000	14,000	10,000	20,000
Discharge	14,000	14,000	14,000	14,000	14,000	8,800	8,800
Residual	16,000	12,000	8,000	4,000	0	1,200	11,200
Charge	10,000	10,000	10,000	10,000	10,000	18,800	18,800
Final Cap	26,000	22,000	18,000	14,000	10,000	20,000	30,000



TIC Systems Power Consumption

- TES Charge cycle (off-peak)

Item	Qty	Power Consumption (kW)
VIM System	1	382
Supporting Chiller	1	868
Coolant Pump	1	55
Total:		1,305

- TES Discharge cycle (on-peak)

Item	Qty	Power Consumption (kW)
Circulation Pump	1	75
Coolant Pump	1	75
Total:		150



Results

- Required modifications
 - SPRINT™: Full injection
 - Turbine's controls system
- Load shift (on-peak to off-peak): about 2 MW
- Increase in turbine's electric output: about 4.3 MW
due to the very low inlet temp.: 42 °F
- Total gross electric power output: 51.3 MW
about 12% increase in electric power output



Results

Operation Data Summary	
Discharge Period (weekdays, on-peak)	8-hours
Annual estimated recharge hours (VIM Operation hours, off-pk)	2,628
Charge cycle power consumption, off-peak (MW)	1.305
Annual power consumption to recharge TES, off-peak (MW-h)	3,430
Annual estimated discharge hours (on-peak)	1,680
Discharge cycle power consumption, on-peak (MW)	0.15
Annual power consumption to discharge TES, on-peak (MW-h)	252
Avoided parasitic power consumption, on-peak (MW)	2
Annual avoided parasitic power consumption, on-peak (MW-h)	3,360
Estimated added power capacity, on-peak (MW)	4.3
Annual added electric power output (MW-h)	7,224
Total annual increase in net off-peak consumption (MW-h)	3,430
Total annual increase in net on-peak production (MW-h)	10,584

Conclusion

- Current configuration
 - “On-demand” chiller: cooling demand 1,711 Tons during on-peak hours
- Proposed configuration
 - VIM TES: cooling demand only 1,100 Tons, and shifted to be during off-peak hours
 - Improved chiller seasonal efficiency
- Benefits:
 - *Electric output increase: about 12%*
 - *Chiller power consumption reduced: about 25%*
 - *Increased level of redundancy*
 - *Environmentally friendly GREEN solution*



Thank You: shlomir@ide-tech.com

Q & A

